



INDUSTRIAL CONSULTANCY CELL

(Member of Consultancy Development Centre, Supported by DSIR, Ministry of Science & Technology, New Delhi)

Address : Kakatiya Institute of Technology & Science Campus
(Autonomous)

Opp: Yerragattu Hilllock, Vill: Bheemaram, Mdl: Hasanparthy, Warangal - 506 015 TELANGANA

ICC

1920

160

Phone : 0870 - 2564322, 2564888

No. ICC/CED/Water/CW-1920040/

Date: 14.06.2019

To
The Principal,
SPR SCHOOL OF EXCELLENCE HIGH SCHOOL
Yellapur, Hasanparthy(Mdl),
Warangal (Dist), T.S.

Sir,

Sub: Water Analysis report — Reg.
Ref: Your Lr.No.Nil, Dated:13.06.2019.

With reference to the subject cited under reference, the water samples which was received at our laboratory by your representative and the results of which are given below:


Sl.No	Constituents	Result	Limits / Range for drinking
1	pH Value	6.50	6.5 to 8.5
2	Odour	Unobjectionable	Threshold number not greater than 3 for public water supply
3	Colour	colourless	Satisfactory
4	Total alkalinity	NIL	Less than 250 mg/L
5	Chloride	3.545 mg/L	Less than 250 mg/L-drinking
6	Total hardness	10.00 ppm	Less than- 350 ppm
7	Conductivity	80 μ mhos/cm	1500 μ mhos/cm
8	Total dissolved solids	20 mg/L	500mg/L - Drinking
9	Degree of hardness	10.00 mg/L	Less than 500ppm
10	Hardness as Ca	10.00 ppm	100.00 ppm
11	Hardness as Mg	Nil	60.00 ppm
12	Nature of the water	Neutral	Neutral - pH=7

Note: The above water sample is suitable for drinking purpose.


(Dr. D. Prabhakara Chary)
Consultant


(Dr. M. Srikanth)
Coordinator


PRINCIPAL


Principal
SPR School of Excellence
Yellapur, Mdl: Hasanparthy,
Dist: Warangal (U)-506371.

File No.HLTH-SCOIS/24/2018-JR AST HLT C-II



GREATER WARANGAL MUNICIPAL CORPORATION

వరంగల్ మహానగర పాలక సంస్థ

CNo.2/F1/35525/2018

Dated:03-01-2019

e-Office Computer No: 67132

HLTH-SCOIS/24/2018-JR AST HLT C-II

NO OBJECTION/SANITARY CERTIFICATE

This is to certify that, on the basis of the inspection report of the Sanitary Inspector concerned, Greater Warangal Municipal Corporation the building premises bearing Municipal H:No:- 53-1-93, **SPR SCHOOL OF EXCELLNCE HIGH SCHOOL**, for the year 2018-2019 is well ventilated with sufficient doors and windows with lighting provided with lavatories and Urinals, water supply and accommodation of class rooms with sufficient space for the students duly white washed having open place within the above building premises for play ground-etc., as per Sanitary conditions in the said building.

The Sanitary certificate issued subject to the conditions, if any legal dispute found in the future sanitation certificate will be cancelled without notice to the applicant/Management.

To,

The Secretary / Correspondent
SPR SCHOOL OF EXCELLENCE ,
HANAMKONDA,
WARANGAL

Signature valid

Digitally signed by BOJIMANA
RAJAREDDY
Date: 2019.01.05 13:56:48 IST
Reason: Approved

Principal
SPR School of Excellence
Yellapur, Mdl: Hasanparthy,
Dist: Warangal (U)-506371.