



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
RENEWAL of NO OBJECTION CERTIFICATE**



Ack. No.:	202970002019	Issue Date :	26/08/2019
NOC:	0006800/RENEWAL/Warangal - Urban/2019		
NOC TYPE:	RENEWAL*		



Valid Upto:	25-08-2024
Applicant Details:	Jagan,9246905445,M/S.SPR School of Excellence.H.No.53-1-122/5,Yellapur.Hasanparthy, Warangal
Building for which NOC issued:	M/S.SPR School of Excellence.,M/S.SPR School of Excellence.H.No.53-1-122/5,Yellapur,Hasanparthy, Warangal/-Yellapur/Hasanparthy/Warangal - Urban

Concessions in Setbacks Given in Lieu of Land Surrendered in Road Widening:	No		
Plot Area (Sq. Mtrs) :	7098.00	Height (Metres):	9.00
Open Spaces (Metres):	North: 6.00	South: 3.00	East: (F) 6.00 West: 3.00
No. of Floors: 0 Cellars, 0 Stilts, 1 Ground, 2 Floors, 0 Terrace	Occupancy Type:		EDUCATIONAL B-1 Schools up to senior secondary level
Total Built-up Area (Sq.Mtrs):	4762.68	Staircases:	No. of Staircases Required/Proposed: 2
Fees Paid (₹):	35000		Aggregate Width Required/Proposed (Metres): 3.40

Fighting Installations Provided as per Table 23, Part-IV of NBC, 2005:

Fire Extinguisher:	12	First Aid Hose Reel:	6	Wet Riser:	0												
Down Comer:	2	Yard Hydrant:	0	Automatic Sprinkler System:	0												
Manually Operated Electronic Fire Alarm Systems:	0	Terrace Tank (Litres):	10000														
Automatic Detection and Alarm System:	0	Underground Static Water Storage Tank (Litres):	0														
Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm ² at Terrace Level	<table border="1"> <thead> <tr> <th>Type</th> <th>Quantity</th> <th>(Capacity in Litres/min)</th> </tr> </thead> <tbody> <tr> <td>Electrical</td> <td>0</td> <td>0</td> </tr> <tr> <td>Diesel</td> <td>0</td> <td>0</td> </tr> <tr> <td>Jockey</td> <td>0</td> <td>0</td> </tr> </tbody> </table>					Type	Quantity	(Capacity in Litres/min)	Electrical	0	0	Diesel	0	0	Jockey	0	0
Type	Quantity	(Capacity in Litres/min)															
Electrical	0	0															
Diesel	0	0															
Jockey	0	0															
Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm ²	<table border="1"> <thead> <tr> <th>(Capacity in Litres/min)</th> </tr> </thead> <tbody> <tr> <td>450</td> </tr> </tbody> </table>					(Capacity in Litres/min)	450										
(Capacity in Litres/min)																	
450																	

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"

** For details and conditions of Renewal No Objection Certificate for Occupancy, refer overleaf.

Head Master

SPR School of Excellence High School (E.M.)
Vill: Yellapur, Mdl: Hasanparthy, Dt:WGL(U).